CERTIFICATE OF CONFORMITY

Issued to: HDL Automation Co., Ltd.

No.86 Lotus west Road, Lifeng Street, Shilou Town, Panyu District, 511447

Guangzhou, Guangdong, China

For the product: Hybrid inverter

Trade name: xenterra

Type/Model: ME-GSE-S5K, ME-GSE-S4.6K, ME-GSE-S3.6K

Ratings: See the annex

Manufactured by: HDL Automation Co., Ltd.

No.86 Lotus west Road, Lifeng Street, Shilou Town, Panyu District, 511447

Guangzhou, Guangdong, China

Requirements: EN 50549-1:2019

EN 50549-1:2019/C1:2019 EN 50549-1:2019/A1:2023

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no. 4924033.50.

The examination has been carried out on one single specimen of the product. The Attestation does not include an assessment of the manufacturer's production. Conformity of this production with the specimen tested by DEKRA is not the responsibility of DEKRA.

This Test Certificate expires at the latest on 7 March 2030 or expires upon withdrawal of one of the above-mentioned standards.

Shanghai, 7 March 2025 // Number: 4924033.01COC

DEKRA Testing and Certification (Shanghai) Ltd.



Rosa Zhou Certification Manager THE MARK OF MULTILATER PROPERTY OF MULTIPATER PROPERTY OF MULTIPATER



PCA-141

 $\ensuremath{\mathbb{C}}$ Integral publication of this certificate and adjoining reports is allowed

DEKRA Testing and Certification (Shanghai) Ltd.

No.250, Jiangchangsan Road, Jing'an District, Shanghai, 200436 People's Republic of China

T +86 21 6056 7600 F +86 21 6056 7555 www.dekra-product-safety.com

ESA-CER-F021 v4.1



Annex to 4924033.01COC

Ratings of the testing Power Conversion System:

Model	ME-GSE-S5K	ME-GSE-S4.6K	ME-GSE-S3.6K
PV input terminal parameters:			
Maximum input power [kW]	5.5	4.8	3.8
Maximum input voltage [VDC]	550		
Rated input voltage [VDC]	380		
MPPT voltage range [VDC]	90-500		
MPPT voltage range (full load) [VDC]	220-500		
Maximum input current [ADC]	13/13		
Isc PV [ADC]	18/18		
Battery terminal parameters:			
Battery voltage range [VDC]	450-550		
Rated voltage [VDC]	450		
Maximum input power [kW]	5	4.6	3.6
Maximum continuous input current [ADC]	11.1	10.2	8
Maximum output power [kW]	5.5	4.8	3.8
Maximum continuous output current [ADC]	12.2	10.6	8.4
AC terminal parameters:			
Rated voltage [VAC]	220/ 230/ 240, 1P+N+PE		
Rated frequency [Hz]	50/ 60		
Maximum continuous input current [AAC]	22.7	20.9	16.3
Maximum input power [kVA]	5	4.6	3.6
Maximum continuous output current [AAC]	25	21.8	17.3
Maximum continuous output power [kVA]	5.5	4.8	3.8
Power factor	0.85 lagging - 0.85 leading		
General			
Operating temperature range	-25~+60°C (derating above 40°C)		
Protective class	Class I		
Ingress protection	IP65		

--- End ---